

CERTIFICATE OF CONFORMITY FOR INTERPOLATION

The undersigned Company **CS THERMOS SRL**, in conformity with the standard rule EN 303-5:2012, as set out in chapter 9.2.1 of the standard itself, states that Lyra 16 and Lyra 27 models, for interpolation, are representative of the models:

- LYRA 19
- LYRA 23

The relative values given by the interpolation are shown in the table below:

	Measured/calculated value at nominal power at 13% O₂			
Model	LYRA 16	LYRA 19	LYRA 23	LYRA 27
Nominal Power	17kW	19,6kW	22,3kW	26,1kW
Efficiency	93,78%	93,40%	93%	92,60%
CO	0,12g/Nm ³	0,153 g/Nm ³	0,185 g/Nm ³	0,23g/Nm ³
OGC	8,3mg/Nm ³	8 mg/Nm ³	7,64 mg/Nm ³	7,3mg/Nm ³
Dust	15,6mg/Nm ³	15,9 mg/Nm ³	16,3 mg/Nm ³	16,7mg/Nm ³

Yours Sincerely,

CS THERMOS SRL

Sigismondo Canzian

